

Note to Specifiers: This specification has been provided in CSI format. Contact Surebond, Inc. at (888) 447-8731 or (877) 843-1818 for other formats you may require.

This Joint Sand Stabilizer section is intended to incorporate the specific elements that make up a good quality product and calls out some installation methods that help produce a good quality installation. The format should be modified to fit within the larger set of specification used on you project

SECTION XXXX PART 1 - GENERAL

1.01 SUMMARY

- A. **Section Includes:** Furnishing of all labor, materials, services and equipment necessary for the supply and installation of breathable pavement sealer to concrete structures as indicated on drawings and as specified herein.
- B. **Related Sections:**
 - 1. Section 03100 - Concrete Work

1.02 REFERENCES

- A. **Applicable Standards:** The following standards are referenced herein.
 - 1. American Society for Testing and Materials (ASTM)

1.03 SYSTEM DESCRIPTION

- A. **Breathable Concrete Sealer** - Clear, epoxy modified, penetrating, breathable, pavement sealer.

1.04 SYSTEM PERFORMANCE REQUIREMENTS

- A. **Testing Requirements:** Pavement sealer shall be tested in accordance with the following standards and conditions, and the testing results shall meet or exceed the performance requirements as specified herein.
- B. **Independent Laboratory:** Testing shall be performed by an independent laboratory meeting the requirements of ASTM E 329-95 and certified by the United States Bureau of Standards. Testing laboratory shall obtain all concrete samples and waterproofing product samples.
- C. **Permeability:** The sealer shall have a zero water penetration rate as defined by ASTM E 514 Item 9.1.4.
- D. **Water Vapor Transmission:** The sealer shall have a minimum water vapor transmission rate of 60 grams/meter²/day at an average dry film thickness of 3.5 to 4.0 mils and a relative humidity of 40% when tested as per ASTM D 1653.

1.05 SUBMITTALS

- A. **General:** Submit listed submittals in accordance with conditions of the Contract and with Division 1 Submittal Procedures Section.
- B. **Product Data:** Submit product information, including manufacturer's specifications, installation instructions, manufacturer's recommendations, and manufacturer's certification or other data substantiating the product complies with requirements of these Contract Documents.
- C. **Manufacturer's Certification:** Provide certificates signed by manufacturer or manufacturer's representative certifying that the materials to be installed comply in all respects with the requirements of this specification.
- D. **Installer:** The installer shall provide a list of projects, including references with contact information, demonstrating at least 5 years of experience in the application of the sealer or similar materials.

1.06 QUALITY ASSURANCE

- A. **Manufacturer:** The manufacturer shall have no less than 10 years experience in manufacturing the sealer or similar products.
- B. **Installer:** The installer shall demonstrate to the satisfaction of the Architect/Engineer an acceptable level of experience in the installation of the sealer or similar products.
- C. **Pre-Installation Conference:** Prior to installation of sealer, conduct meeting with the installer, general contractor and Architect/Engineer, owner's representative, and waterproofing manufacturer's representative to verify and review the following:
 - 1. Project requirements for materials and installation as set out in Contract Document.
 - 2. Manufacturer's product data including application instructions.
 - 3. General site conditions, schedule, coordination with other activities, line and grade of the work, substrate conditions, procedures for substrate preparation and cleanup.

1.07 DELIVERY, STORAGE AND HANDLING

- A. **Delivery:** Deliver packaged materials to project site in original undamaged containers, with manufacturer's labels and seals intact.

1.08 MATERIALS

- A. The material shall be an epoxy-modified joint sand stabilizer and concrete sealer, capable of penetrating and sealing the surface of the paver without causing a glossy or shiny effect.
- B. The material, as delivered, will be liquid at typical ambient temperatures It shall have a VOC of less than 100 grams per liter.

- C. The material shall be designed to be installed after the joint sand has been installed.
- D. The product shall be manufactured as a joint sand stabilizer and labeled as such.
- E. The material shall comply with the criteria in 1.04 of this section.
- F. Material shall be water based and shall not contain solvents.

1.08 PROJECT CONDITIONS

- A. Comply with manufacturer's product data regarding condition of substrate to receive penetrating sealer, weather conditions before and during installation, and protection of the installed materials.
- B. Prior to the installation of the stabilizer all other pavement related work shall be completed, including but not limited to installation of bedding sand, edge restraints, pavers, and joint sand, to final alignment and elevation. The surface shall be clean and free from any staining, oil, dust, loose material or any other substance interfering with the penetration of the liquid material into the joint sand or the surface of the pavers. The surface of the paver and the joint sand, to the full depth of the joint, shall be dry.
- C. Work shall not commence if rain or other precipitation is predicted in the area for the period of the installation and 24 hours thereafter.

1.09 EXECUTION

- A. The sealer shall be applied as per the manufacturer's data sheet and these Construction Documents.
- B. The manufacturer's recommended coverage rate shall be followed.
- C. Prepare a test area of 100SF for review of and approval by the Architect/Engineer. The test area shall include at least one example of every type of joint or material to be sealed. Do not proceed with the balance of the work until approval, in writing, is received. Upon approval the test area may be incorporated into the work.
- D. The surface to receive the sealer must be clean, dry and free of loose materials or chemicals (including curing compounds).
- E. Do not apply sealer if the temperature of the concrete is below 50°F or above 115°F, or if the air temperature is at or below 58°F and falling or at or above 90°F and rising. Do not apply the sealer if rain is predicted in the area within the following 36 hours.
- F. The joint sand stabilizer shall be applied evenly using a low-pressure system with a nozzle pressure not exceeding 25 psi. Manual or electro-mechanical systems are acceptable.
- G. Draw the excess sealer off the surface with a soft squeegee or sponge roller.
- H. Do not allow excess sealer to remain on the surface.

- I. Remove all spillage promptly and rinse affected area with water.
- J. Do not allow foot or vehicle traffic on the sealed surface for 24 hours after application.
- K. When in conflict with any other portion of these specifications, the manufactures recommended installation methods shall be followed, except that in all cases the material shall be worked into the sand joints and the surface of the pavers using appropriate squeegees. Joints shall be adequately flooded and that no surplus material shall be left on the surface of the pavers or on the tops of the joints.

1.09 EXECUTION

- A. Work shall cease if inclement weather (rain or strong wind) will affect the stabilizing operation and shall not recommence until the joint sand and the surface of the pavers have dried.
- B. The treated area shall be protected from rain, sprinklers, or any other form of moisture, and traffic for 24 hours after completing the application of the stabilizer.

END OF SECTION